

FLAMEFIGHTER III EXTINGUISHER RANGE

	1KG Dry Powder	1.5kg Dry Powder	2kg Dry Powder	2.5kg Dry Powder
Agent Capacity	1.0kg	1.5kg	2kg	2.5kg
Agent Type	ABE	ABE	ABE	ABE
Gross Weight	1.85kg	2.84kg	3.49kg	4.53kg
Height (Base to tip handle)	310mm	320mm	375mm	365mm
Width (Cylinder)	93mm	113mm	110mm	130mm
Discharge Time	9 sec	13 sec	16 sec	18 sec
Cyl Pressure Test	2.8MPa	2.8MPa	2.8MPa	2.8MPa
Fire Rating	2A:10B:E	3A:20B:E	3A:30B:E	4A:40B:E
Approval	AS/NZS 1841.5	AS/NZS 1841.5	AS/NZS 1841.5	AS/NZS 1841.5

	4.5 KG Dry Powder	6kg Dry Powder	9kg Dry Powder	2kg CO2
Agent Capacity	4.5kg	6kg	9kg	2kg
Agent Type	ABE	ABE	ABE	CO2
Gross Weight	7.36kg	9.7kg	13.76kg	5.18kg
Height (Base to tip handle)	450mm	550mm	533mm	530mm
Width (Cylinder)	146mm	165mm	183mm	110mm
Discharge Time	24 sec	20 sec	29 sec	8 sec
Cyl Pressure Test	2.8MPa	2.5MPa	2.8MPa	25MPa
Fire Rating	10A:60B:E	4A:80B:E	10A:80B:E	2B:E
Approval	AS/NZS 1841.5	AS/NZS 1841.5	AS/NZS 1841.5	AS/NZS 1841.6

	3.5 KG CO2	5kg CO2	2L Wet Chemical	7L Wet Chemical
Agent Capacity	3.5kg	5kg	2L	7L
Agent Type	CO2	CO2	WC	WC
Gross Weight	9.27kg	12.16kg	4.33kg	10.26kg
Height (Base to tip handle)	583mm	678mm	400mm	595mm
Width (Cylinder)	140mm	152mm	110mm	160mm
Discharge Time	11 Sec	13 sec	14.5 sec	60 Sec
Cyl Pressure Test	25MPa	25MPa	2.5MPa	2.5MPa
Fire Rating	10B:E	10B:E	1A:4F	3A:4F
Approval	AS/NZS 1841.6	AS/NZS 1841.6	AS/NZS 1841.3	AS/NZS 1841.3



FLAMEFIGHTER III EXTINGUISHER RANGE

	9L Water	9L Foam
Agent Capacity	9L	9L
Agent Type	WATER	Florine Free Foam
Gross Weight	12.58kg	12.88kg
Height (Base to tip handle)	590mm	586mm
Width	180mm	181mm
Discharge Time	70 sec	45 sec
Cyl Pressure Test	2.5MPa	2.5MPa
Fire Rating	3A	4A:20B:3F
Approval	AS/NZS 1841.2	AS/NZS 1841.4

MINIMUM EFFECTIVE DISCHARGE TIMES

Extinguisher nominal charge. Minimum duration of discharge in seconds.

KG or L	Water and Wet Chemical	Foam	Dry Powder
<2	10	10	8
>2	30	20	9
>6	45	30	12
10	45	30	15

